TOWN OF BLACK MOUNTAIN
STAFF REPORT: Major Subdivision – 070092305300000 (334 North Fork Rd.)
Prepared for November 17, 2025, Planning Board Review of Subdivision Plat

REQUEST

Applicant:

Paul Sexton, Three Notch Group, 122 Lyman St., Asheville, NC 28801

Proposal:

Via the major subdivision process, subdivide 070092305300000 (334 North Fork Rd.) into 12 lots

Relevant Ordinance Sections:

Chapter 3 (Subdivisions) of the Land Use Code

- Section 3.1 (Purpose and Applicability)
- Section 3.2 (General Legal Provisions)
- Subsection 3.3.3 (Major Subdivision), which details the steps:
    - Step **1**: Technical review meeting with staff with sketch plan (completed on 3/4/2025).
    - Step **2**: Planning Board review of sketch plan (10/27/2025).
    - Step **3**: Planning Board review of preliminary plat (11/17/2025). Planning Board takes one of three actions on the preliminary plat:
        - approve;
        - approve with modifications;
        - or, deny.
    - Step **4**: Applicant submits construction drawings and supporting documentation for each phase or phases of development; if the preliminary plat was approved with modifications by the Planning Board (***Step 3***), the applicant submits a revised plat reflecting such changes.
    - Step **5**: Applicant installs or guarantees required improvements and/or infrastructure.
    - Step **6**: Applicant submits final plat (must be done within two years of Planning Board approval of preliminary plat).
    - Step **7**: Subdivision administrator takes one of three actions on final plat within 15 days of submission of the final plat: approve, disapprove, or approve subject to minor modifications. As part of this step, applicant files the plat for recording with Buncombe County. No permits shall be issued by the Town for individual lots until the plat is recorded with the county.
- Section 3.4 (Subdivision Requirements), which details the requirements for sketch plans, preliminary plats, and final plats
- Section 3.5 (Subdivision Design Standards), which details requirements for:
    - Lots
    - Streets
    - Utilities (water supply and sanitary sewage collection and disposal)
    - Entryways to Subdivisions
    - Pedestrian Circulation (internal pedestrian circulation and points of connectivity with exterior transportation corridors)
    - Open Space
    - Improvement Guarantees
    - Traffic Impact Analysis (applicable if 798 or more daily trips will be generated)
- Section 3.6 (Dedication and Closures of Rights-Of-Way or Easements to the Town) (if applicable)

Chapter 4 (Zoning) of the Land Use Code

- Section 4.7.15 (Dimensional Requirements by Zoning District)
  - Town Residential (TR-4): minimum lot size: ¼ acre; minimum lot width: 40 feet (15 feet at street); minimum lot depth: 80 feet

Article IX (Stream Buffer Protection Standards) of Chapter 20 (Environment) of the Code of Ordinances

DETAILS OF PROPOSAL

The following is an overview of the parcel and a summary of the subdivision application:

The property is in the Town Residential (TR-4) zoning district. The clip below is from Buncombe GIS – pale yellow is TR-4, dark purple is Suburban Residential (SR-2), and light purple is Conservation Residential (CR-1). (Image is *Post Helene 2024*.)



The surrounding lots are:

	North	South	East	West
Adjacent Zoning Designation	CR-1	324 North Fork Rd., which borders to the south and east, is split-zoned. The portion that borders to the south is TR-4; the portion that borders to the east is SR-2.		CR-1
Adjacent Land Uses	Single-Family Residences	Single-Family Residence		Town of Black Mountain golf course

The ***Purpose and Intent*** of the TR-4 zoning district is:

> The town residential district is established to allow for a variety of housing types while maintaining an overall residential character with medium density. Any use which, because of its characteristics would interfere with the residential nature of the area is excluded.


Reference: Section 4.7.3 (Town Residential District – TR-4) of Chapter 4.

Existing Conditions

According to the applicant's engineer-stamped draft preliminary plat, the parcel is 4.38 acres (190,792 square feet) in size. The Buncombe County Property Record Card lists the following structure on the parcel: 2,704 square foot single-family residence built in 2024.

The overall slope of the lot is 8.75 percent (according to https://www.mapwnc.org/find-slope-for-parcel).

Below is a clip from Buncombe GIS with the *5 Foot Contours*, and *Stream & River* layers turned on. The property is within 50 feet of a USGS 'watercourse' on the east side of the parcel that is also a waterway classified by the NC Department of Environmental Quality: Tomahawk Branch. (The property is not in the 100-year floodplain.) Image is *Post Helene 2024*.



ANALYSIS

CONSISTENCY WITH ADOPTED POLICY GUIDANCE:

The applicant incorporated feedback on their sketch plan that was conveyed by the Planning Board at their 10/27/2025 meeting (***Step 2***).

Step 3 is Planning Board review of sketch plan as described in Section 3.3.3 (Major Subdivision):

Step 3: Planning board review and approval of preliminary plat

A. The applicant shall submit preliminary plat to the subdivision administrator who shall place the item on the agenda of the next regularly scheduled planning board meeting along with his or her recommendation as to whether the preliminary plat should be approved.

B. Notice shall be given as provided in section 1.5.4.F.

C. Before the planning board reviews the preliminary plat, the following agencies shall be given an opportunity to make recommendations concerning the proposed subdivision plat:

1. The district highway engineer as to the any proposed state streets, state highways, and related drainage systems;
2. The county health director, public works director, MSD representative, and representatives of any other local public utility, as appropriate, as to proposed water or sewerage systems;
3. The fire marshal; and
4. The stormwater and floodplain administrator(s).

D. The planning board shall review the plat for conformity with the requirements of this land use code and shall either approve, approve with modifications, or deny the application for approval of the preliminary plat.

Sections 3.4 (Subdivision Requirements) and 3.5 (Subdivision Design Standards) list the requirements for preliminary plats and final plats. Staff review found the following:

The sketch plan must contain the following information at a minimum (per Sec. 3.4.1 [Sketch Plans]):	✓ = staff analysis finds that the required element is on the sketch plan
1. The name of the subdivision, the proposed use and the name, address, and phone number of the owner.	✓ Myers North Fork Road Subdivision. David Myers, 56 Legacy Lane, Blk Mtn 28711
2. A vicinity map showing the location of the subdivision in relation to neighboring tracts, subdivisions, roads, or nearby buildings and their zoning and uses.	✓
3. The boundaries of the tract.	✓
4. Total acreage of the tract and the portion of the tract to be subdivided.	✓
5. Location of significant natural features such as water courses, ponds, rock outcroppings or forest.	✓ **Tomahawk Branch**, along the east side of the parcel, including the *Stream Buffer*, is depicted; this complies with the requirements of the Stream Buffer Protection Standards.
6. Topography at five-foot intervals and the location of existing drainages or swales.	✓
7. Location of flood hazard areas from FIRM map.	N/A
8. Location of existing or proposed utilities.	✓
9. Existing street and lot layout and dimensions, including rights-of-way.	✓
10. Proposed new lot layout and dimensions and any rights-of-way or driveways to be built. Road specifications are indicated in the Town of Black Mountain Standards and Details Manual.	✓

	11. Designated open space, greenway or park space that is a minimum of five percent of the total land area of the original tract. Designation of easements to the town for parks and greenways according to the town's pedestrian plan, greenway master plan or recreation and parks plan can qualify for the dedicated open space requirement but must be approved by the town council and planning board in consultation with the planning director and the recreation and parks directors.	✓ 1.32 acres (56,905 SF) of open space is proposed. 1.32 acres is 30% of the parcel size of 4.38 acres (190,792 SF).
	12. Sidewalks or greenways which serve all occupiable lots and of equal or greater linear feet than the total linear footage of the subdivision road. Linear greenway easements may count toward the five-percent open space requirement.	✓ The following is shown: *4' Wide Mulch Pathway to Common Open Space / 10' Access Easement (5' Each Side of Path)*
	13. A statement from the town water department and/or MSD that adequate water and sewer service may be provided to the lot(s). If the subdivider intends to use on-site septic, then a statement from the Buncombe County Health Department must be included that indicates that the created lots have septic or are appropriate for septic systems. (Sec. 3.5 requirement: At the time of submitting the preliminary subdivision plat, the applicant must submit "satisfactory evidence as to the proposed method and system of water supply and sanitary sewage collection and disposal.")	✓ **WATER**: Applicant submitted a statement from Chris Sloan, Operations Manager, Public Works Department, dated 3/25/2025 confirming water availability. **MSD**: Applicant submitted a completed MSD *Wastewater Allocation Request* dated 4/28/2025 with the following information: - Manhole Connection Point: "12 Lot subdivision connecting to MSD Manhole #57-101335." - Project Description: Proposed 12 lot subdivision with frontage on two existing roads (North Fork Rd., Walker Cove Rd.). Proposed installation of six new manholes and 479 linear feet of 8" sewer main."

REPORT PREPARATION

This report was prepared by Planning Department staff member Russell Cate, Planner/Zoning Administrator, and reviewed by Michelle Kennedy, Planning Director.